

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0992:104 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Napco, 333 Bayview Ave., Amityville, NY 11701
Contact: *Edmund Gregorian (631) 842-9400 ext 270 Fax (631) 842-2726

DESIGN: Models MAGNUM FIRE ALERT 6024 and 6012. Inherently power-limited; non-coded local, auxiliary remote station protected premises and central station protected premise service; automatic, manual and waterflow service. Suitable for sprinkler supervisory service as a local and central station protected premise unit. Refer to listee's data sheet for detailed product description and operational considerations. Basic system:

6024/6012	Control Panel
M6000	Reverse Polarity Subassembly

OPTIONS: Refer to listee's data sheet for required/optional accessories. When required, accessories shall be CSFM listed.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a control unit for use with separately listed compatible initiating and indicating devices. Presignal operation not approved.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Burglary and other non-fire functions were not examined.

*Rev. 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**